

MANAGING DIRECTORS
MATTHEW PALAVIDIS
VICTOR FATTORETTO

DIRECTORS
MATTHEW SHIELDS
BEN WHITE




2012002/3001A/R0/RL

30/01/2012

Acoustic Supplies
28 Norton Street
Randwick NSW 2031

Hard Floor Test Report

Acoustic Logic has tested the acoustic performance of the following floorboard system:



SYDNEY
A: 9 Sarah St Mascot NSW 2020
T: (02) 8339 8000
F: (02) 8338 8399

SYDNEY MELBOURNE BRISBANE CANBERRA
LONDON DUBAI SINGAPORE GREECE

www.acousticlogic.com.au
ABN: 11 068 954 343

The information in this document is the property of Acoustic Logic Consultancy Pty Ltd ABN 11 068 954 343 and shall be returned on demand. It is issued on the condition that, except with our written permission, it must not be reproduced, copied or communicated to any other party nor be used for any purpose other than that stated in particular enquiry, order or contract with which it is issued.

The above flooring system achieves the following ratings:

Table 1 - Floor Impact Test Results - $L_{ntw} + C_1$

Source Room to Receiving Room	Measured Results	
	FIIC	$L_{ntw} + C_1$
	56	50

We trust this information is satisfactory. Please contact us should you have any further queries.

Yours faithfully,



Acoustic Logic Consultancy Pty Ltd
Remi Larmandieu